

Space Heater Use on Campus

1 Purpose

Methodist University is committed to providing a safe environment for all activities under its jurisdiction. In keeping with this commitment, the University has developed this policy to protect the University community and its visitors from the significant fire and workplace safety risks posed by the use of space heaters. This policy is in keeping with the requirements of the North Carolina Fire Code and North Carolina Occupational Safety and Health Division (OSHA).

Space heaters pose serious fire and electrical hazards, and are not efficient from an energy use standpoint; therefore, the use of space heaters at the University is strongly discouraged.

2 Scope of application

This policy applies to the use of portable space heaters in indoor settings (offices, workshops, resident halls, classrooms, etc.) within Methodist University buildings or other buildings used by Methodist University employees and students. This policy is meant to outline the minimum requirements for the safe use of portable indoor space heaters.

The local Fire Marshal may further restrict use of portable indoor space heaters per local fire code or ordinance

	Name	Function
Written	Dempster, Matthew	Director of Environmental, Health, and Safety
Approved	Dockery, Steve	Assistant Director of Facilities
	Kinsey, Sheila	Vice President for Planning & Administration

	Issue
Previous	Original

Contents

	Page
1 Purpose.....	1
2 Scope.....	1
3 Definitions / Terms / Abbreviations.....	2
4 Space Heater Use.....	2
4.1 Limited Use Approval.....	3
4.2 Target Temperature Not Maintained.....	3
4.3 Specific Health Needs.....	3
5 Safety and Use Requirements for Space Heaters.....	3
5.1 Product Design.....	3
5.1.1 Electrically Powered.....	3
5.1.2 Thermostat.....	4
5.1.3 Tip-Over Protection.....	4
5.1.4 Overheat Protection.....	4
5.2 Operating Requirements.....	4
5.2.1 Placement.....	4
5.2.2 Inspection.....	5
5.2.3 Power Cord.....	5
5.2.4 Shut Off.....	5
6 Referenced Documents.....	5
7 Document History.....	6
8 Supplementary Sheets.....	6

3 Definitions / Terms / Abbreviations

Space Heater

A space heater is a self-contained device for heating an enclosed area.

4 Space Heater Use

This policy does NOT apply to the following:

- The temporary use of portable heaters for construction, outdoor settings, or industrial/research support applications is outside the scope of this policy. Use in these circumstances should be governed by the work hazard planning process in place at the campus.
- Non-portable area heaters that are wired or plumbed into the building utilities by the campus facilities department or included in building construction are not covered under this policy.

- Heated footrests or heated floor mats of 200W or lower power are not considered space heaters under this policy.

4.1 Limited Use Approval

Appropriate adjustment of the building heating system should always be the preferred option for meeting the heating needs for employees, students and guests in Methodist University buildings. When this is infeasible, occupants shall have the authority to approve the use of certain space heaters in limited situations, such as where target temperatures cannot be maintained, for specific health needs, or for other extenuating circumstances. Under limited use approval, the selection and use of the space heater should follow the criteria in the Safety and use requirements for space heaters section, below.

4.2 Target Temperature Not Maintained

If the central building heat system is unable to maintain a target work temperature, it may be determined that it is necessary to allow a space heater for temporary, supplemental heat until the comfort concern can be permanently resolved.

4.3 Specific Health Needs

The reason for the exemption should be documented. For example, if there is a medical reason, a document from a medical provider should be provided.

5 Safety and Use Requirements for Space Heaters

It is essential to ensure the safe and responsible use of the portable space heater in order to reduce the risk of fire. In the event an exemption is granted, only space heaters meeting the following criteria are permitted:

5.1 Product Design

5.1.1 Electrically Powered

- The heater must be electrically powered and designated as approved with a nationally recognized testing laboratory mark [common marks include Underwriters Laboratories (UL) or FM Global Technologies (FM)]. Other nationally recognized testing laboratories may certify these products; see <https://www.osha.gov/dts/otpca/nrtl/nrtlmrk.html> for more information.
- Liquid-fuel (propane, kerosene) space heaters are not permitted.

5.1.2 Thermostat

- The space heater must have a thermostat for heat regulation
- Heaters without thermostats (e.g., simple "on/off" or "high/low" switches) are not permitted.

5.1.3 Tip-Over Protection

Space heaters must have a tip-over shutdown feature. If the heater is knocked over, the unit must automatically shut off.

5.1.4 Overheat Protection

Space heaters must have overheat protection, which will automatically shut the unit off if there is an overheat situation

5.2 Operating Requirements

Approved space heaters may be used only if the following conditions are met:

5.2.1 Placement

- The heater may only be located on the floor. Heaters located on filing cabinets, tables, desks or other surfaces are more susceptible to being knocked over, resulting in accidents or fires.
- Heaters may only be placed on circuits sufficiently capable of handling the amperage draw of the heater and other equipment on the circuit. Campuses may set power limitations on approved heaters.
- Heaters may not be used in areas where flammable liquids are in use or stored.

- Student-owned space heaters are not allowed in the campus residence halls or other campus student living facilities.
- Keep the heater away from water and out of damp locations.
- Maintain minimum clearance distances as specified by the manufacturer.
- Combustible or flammable materials must be kept away from the heater

5.2.2 Inspection

- Inspect the heater for broken or damaged parts. Never operate a heater you suspect is damaged.
- During use, check frequently to determine if the heater plug or cord, wall outlet, or faceplate is hot. If the plug, outlet, or faceplate is hot, discontinue use of the heater, and have a qualified electrician check and/or replace the plug or faulty wall outlet(s). If the cord is hot, disconnect the heater, and have it inspected/repaired by an authorized repair person.

5.2.3 Power Cord

- Heaters must be plugged directly into a wall receptacle. Use of extension cords or power strips is not allowed. Electric cords must be kept out of foot traffic paths to prevent tripping.
- Never run the heater's cord under doors, rugs, or carpeting. This can damage the cord, causing it and nearby objects to burn.

5.2.4 Shut-Off

- The heater must be turned off any time the room or area being heated is unoccupied, especially at the end of the workday.

6 Referenced and applicable documents

7 History / participating departments

Changes to previous issue	Small changes to content		
Participated in creation/modification	Last Name, First Name	Function	
	Dempster, Matthew	Author	
Change requests:	Requests shall be sent to the author of the document	Review Cycle	Annually

8 Supplementary sheets